



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2021142  
Permit # 01193-2021REM  
Request Rec'd 10/18/2021  
Amended Date  
Approval Date 10/18/2021 DS  
Permit Expires 4/19/2022

**Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>True North Energy, LLC 10346 Brecksville Road Brecksville, OH 44141  Contact: David Nye (440) 792-4200</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>True North Location 2029 97 S. Kennedy Dr. Carpentersville, IL 60110  Contact: Mathew Ullas (847) 426-4424</p>
---	---

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 6, 7, 8) - 12,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Remove 2 north islands and associated piping

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Anderson Pump Service, Inc.  
19659 South 97th Avenue  
Mokena, IL 60448

Contact Person: Ronald Anderson  
Phone: (708) 478-6190  
Contractor Registration # IL002275 Exp. 6/10/2023

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File