



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2047323
Permit # 01242-2021REM
Request Rec'd 10/15/2021
Amended Date 11/01/2021 DS
Approval Date 10/28/2021 DS
Permit Expires 4/28/2022

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Heil-Chicago Real Estate, Inc. 7801 W. 47th Street McCook, IL 60525 Contact: Albert Majeres (708) 447-3272	(2) <u>FACILITY</u> - name and address where tanks are located: H.C.I. REAL ESTATE 7801 W. 47th Street McCook, IL 60525 Contact: Albert Majeres (708) 447-3272
--	--

(3) **REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 1) - 275*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 1) - Unknown*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES :**

Amendment Reason: Tank contents were pumped out prior to removal and 1,800 gallons of material were pumped out. 275 gallon size was provided by the tank owner.

(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u>	
AQS Services Inc 443 South Clay Street Hinsdale, IL 60521	Contact Person: William Anthony Phone: (630) 789-3345 Contractor Registration # IL1913 Exp. 5/11/2022

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File