



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2026491
Permit # 01278-2021UPG
Request Rec'd 11/03/2021
Amended Date
Approval Date 11/8/2021 DS
Permit Expires 5/10/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Naper Land Mart, Inc. 1303 Plainfield Naperville Road Naperville, IL 60564 Contact: Saju Kannampillil (847) 791-1824	(2) <u>FACILITY</u> - name and address where tanks are located: Naper Mart Inc. 1303 Plainfield Naperville Road Naperville, IL 60564 Contact: Saju Kannampillil (847) 791-1824
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 4) - 15,000, (TK # 5) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 4, 5) Piping - Shear Valves, (TK # 4, 5) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 4) - Gasoline - Premium, (TK # 5) - Gasoline - Regular*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Removing dispensers from around canopy pole and installing new ovation dispensers and new flex connectors to relocate shear valves. Will have 3rd party tank and line test upon completion. Will also be replacing regular fill and vapor manway and addressing the intercom.

NOTE: Per contractor, N.O.V. violations will be addressed at time of permitted work

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Reliable Pump Service and Maintenance
14007 S Bell Road Suite 228


Contact Person: John Baio, Jr.

Homer Glen, IL 60491

Phone: (815) 546-7867

Contractor Registration # IL002433 Exp. 10/7/2022

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File