



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1022902
Permit # 01280-2021UPG
Request Rec'd 11/04/2021
Amended Date
Approval Date 11/8/2021 DS
Permit Expires 5/10/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Mac's Convenience Stores, LLC 550 Warrenville Rd., Suite 400 Lisle, IL 60532 Contact: Ralitsa Valkanova (984) 389-1765	(2) <u>FACILITY</u> - name and address where tanks are located: Circle K #1419 1102 North First De Kalb, IL 60115 Contact: Laretta Wolf (815) 748-7483
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 8) - 12,000

(b) Type of tanks:

(c) Type of piping:

(d) Product to be stored in each tank: (TK # 8) - Gasoline - Premium

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containment devices: (TK # 8) Spill Contain Device - Double Wall Spill Bucket

(h) Overfill prevention devices: (TK # 8) Overfill Prev Device - Overfill Drop Tube Valve

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES : REPLACE THE PREMIUM SPILL, RISER AND DROP TUBE

1. Saw cut and demo around the premium spill bucket, load and dispose of the concrete.
2. Dig to the tank top, remove the 4" riser, spill bucket, drop tube and discard.
3. Install a new 4" riser, spill bucket, overfill drop tube, swivel fill and cap.
4. Water test the spill bucket

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street


Contact Person: Jimmy Spiros

St. Louis, MO 63139

Phone: (314) 772-4501

Contractor Registration # IL1502 Exp. 3/26/2022

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", written in dark ink. The signature is fluid and stylized, with a horizontal line underneath it.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File