



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 7023241
Permit # 01384-2021REM
Request Rec'd 11/29/2021
Amended Date
Approval Date 11/29/2021 DS
Permit Expires 6/1/2022

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Martin & Bayley, Inc. P.O. Box 385 Carmi, IL 62821</p> <p>Contact: Landon Bayley (618) 382-2334 Ext. 248</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Hucks #111 102 West 10th Street Metropolis, IL 62960</p> <p>Contact: Nicole Walker (618) 382-2334</p>
--	---

(3) REMOVAL OF PIPING:

- (a) Description/location of piping being removed:*
- (b) Which tank(s) are associated with the piping being removed: (TK # 3, 4) - 10,000*
- (c) Reason of piping being removed:*
- (d) If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

Pull out existng piping through 4" chase. Install new double wall flex piping sumps and sump sensors

NOTE: Installation of new piping, sumps and sensors will need to be done under a separate upgrade permit

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Hinderliter Construction & Maint., Inc. 3601 North St. Joseph Avenue Evansville, IN 47720</p>	<p>Contact Person: Mark Hinderliter Phone: (812) 425-4137 Contractor Registration # IL646 Exp. 4/2/2022</p>

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File