



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 1012476
Permit # 01419-2021UPG
Request Rec'd 12/08/2021
Amended Date
Approval Date 12/8/2021 DS
Permit Expires 6/8/2022

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Putnam County School Dist #535 400 E Silverspoon Ave. Granville, IL 61326</p> <p>Contact: Carl Carlson (815) 339-6514</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Putnam County High School 402 E Silverspoon Ave. Granville, IL 61326</p> <p>Contact: Tracy Reaska (815) 339-6514</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 4, 5) - 1,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 4) - Diesel Fuel, (TK # 5) - Gasoline - Regular*
- (e) Type of leak detection being used:*

*Tank: (TK # 4, 5) Leak Detect - Tank - Automatic Tank Gauging Pneumercator TMS 2000, (TK # 4, 5) Leak Detect - Tank - Hydrostatic Reservoir Interstitial Monitoring Sensors*

*Piping:*

- (f) Corrosion Protection being used:*

*Tank:*

*Piping:*

- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Removing existing tank monitor. Installing new Pneumercator system. Installing new interstitial sensors in each tank ( Brine Reservoir Sensors). Connecting sensors using existing wires. Startup panel and test.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554	Contact Person: Chris Epkins Phone: (309) 347-1819 Contractor Registration # IL1293 Exp. 2/4/2022

---

Sincerely,

*Daniel G. Starks*

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File