



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 6039251  
Permit # 01420-2021UPG  
Request Rec'd 12/08/2021  
Amended Date  
Approval Date 12/8/2021 DS  
Permit Expires 6/8/2022

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>R &amp; L Carriers, Inc. 600 Gillam Road PO Box 271 Wilmington, OH 45177  Contact: Stephen Shelton (937) 382-1494</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>R &amp; L Carriers Parkway 1740 Sauget Industrial Parkway Sauget, IL 62201  Contact: Chuck Tackett (937) 332-0529</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

*(a) Number and size of tanks being upgraded or repaired: (TK # 3) - 2,000*

*(b) Type of tanks:*

*(c) Type of piping:*

*(d) Product to be stored in each tank: (TK # 3) - Diesel Fuel*

*(e) Type of leak detection being used:*

*Tank:*

*Piping:*

*(f) Corrosion Protection being used:*

*Tank:*

*Piping:*

*(g) Spill containment devices, piping, and dispenser containment devices: (TK # 3) Spill Contain Device - Double Wall Spill Bucket*

*(h) Overfill prevention devices:*

*(i) Manway accessible at grade:*

**(4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES : REPLACE THE TANK 3 DIESEL SPILL BUCKET**


1. Saw cut and demo around the off road diesel spill bucket, there will be an 18" manhole in the demo. Load and dispose of the concrete,
2. Remove and save the fill cap, adaptor and drop tube. (the drop tube is removeable)
3. Remove the spill bucket and replace with an OPW 1C-3112D double wall spill bucket.
4. Reinstall the drop tube, fill adaptor and cap.
5. Water test the spill bucket.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Neumayer Equipment Company, Inc.  
5060 Arsenal Street  
St. Louis, MO 63139

Contact Person: Jimmy Spiros  
Phone: (314) 772-4501  
Contractor Registration # IL1502 Exp. 3/26/2022

Sincerely,



---

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File