



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2032321
Permit # 01444-2021UPG
Request Rec'd 12/09/2021
Amended Date
Approval Date 12/13/2021 DS
Permit Expires 6/14/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>XPO Logistics Freight, Inc. 2211 Old Earhart Rd., Suite 100 Ann Arbor, MI 48105 Contact: Jeff Sexten (734) 757-1657</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>XPO Logistics Freight, Inc. - XDP 401 W. Touhy Ave. Des Plaines, IL 600182403 Contact: Mike Reidy (847) 930-6270</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2) Piping - Fiberglass Single Wall Piping Ameron 4000 L single wall vent, (TK # 1, 2) Piping - Other Steel Riser*
- (d) Product to be stored in each tank: (TK # 1, 2) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :


During the re piping inspection OSFM requestyed to pull permit for vent lines and risers seperately which was not mentioned in the intial permit#01264-2021UPG so we are pulling permit for that scope
 Replaced piping exceeds 20 feet or 50% of the total pipe run.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
America Petropump Services LLC d/b/a Ampsco Services	Contact Person: Ravindra Penmatsa

4075 Fox Valley Center Dr., Unit 9
Aurora, IL 60504

Phone: (312) 286-6722
Contractor Registration # IL002420 Exp. 5/22/2023

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File