



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3000811
Permit # 01469-2021INS
Request Rec'd 12/15/2021
Amended Date
Approval Date 12/20/2021 DS
Permit Expires 6/22/2022

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Blick & Blick Oil, Inc. 203 SE 5th Ave. Aledo, IL 61231</p> <p>Contact: Steve Blick (309) 582-2012</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Blick & Blick Oil, Inc. 203 SE 5th Ave. Aledo, IL 61231</p> <p>Contact: Steve Blick (309) 582-2012</p>
--	--

(3) INSTALLATION OF TANKS:

- (a) *Number and size of tanks being installed: (TK # 10) - 8,000, (TK # 11, 12) - 4,000*
- (b) *Type of tank(s): (TK # 10, 11, 12) Tank - Composite Double Wall Glasteel II*
- (c) *Type of piping: (TK # 10, 11, 12) Piping - Flexible Double Wall A.P.T. Poly Tech P150SC from tanks to transition sumps as shown in site plan, (TK # 10, 11, 12) Piping - Positive Shutoff Valves, (TK # 10, 11, 12) Piping - Shear Valves, (TK # 10, 11, 12) Piping - Single Wall STP/Tanktop Sump, (TK # 10, 11, 12) Piping - Single Wall Transition Sump*
- (d) *Product to be stored in each tank: (TK # 10) - Diesel Fuel, (TK # 11) - Gasoline - Premium, (TK # 12) - E-85*
- (e) *Type of leak detection being used:*
 - Tank: (TK # 10, 11, 12) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD, (TK # 10, 11, 12) Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors*
 - Piping: (TK # 10, 11, 12) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 10, 11, 12) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in submersible and transition sumps*
- (f) *Corrosion Protection being used:*
 - Tank: (TK # 10, 11, 12) Corrosion Prot - Tank - Fiberglass Non-Corrosive, (TK # 10, 11, 12) Corrosion Prot - Tank - Jacketed Steel Non-Corrosive*
 - Piping: (TK # 10, 11, 12) Corrosion Prot - Piping - Flexible Non-Corrosive*
- (g) *Spill containment devices, piping and dispenser containment devices: (TK # 10, 11, 12) Spill Contain Device - Double Wall Spill Bucket*
- (h) *Overflow prevention devices: (TK # 10, 11, 12) Overflow Prev Device - Overflow Drop Tube Valve*

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov by calling (217)785-1020.

(5) **GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping

is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) SPECIAL CONTINGENCIES :

Installing new tanks at location to replace the older tanks. Connecting to the existing piping thru new transfer sumps with new pipe. Reusing the existing tank monitor and line leak detection on the existing tanks. Installing new double wall spill containments and running new vent lines.


NOTE: Database shows existing piping is DW, therefore we will allow a transition sump to be installed to connect new piping to be connected to existing. Sensors must be installed in new STP sumps and new transition sumps.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Central Petroleum Equipment Company
109 Terrace Dr.
Blue Grass, IA 52726

Contact Person: Roger Clark
Phone: (563) 381-5092
Contractor Registration # IL345 Exp. 6/14/2022

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File