



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 7020850
Permit # 01478-2021UPG
Request Rec'd 12/20/2021
Amended Date
Approval Date 12/20/2021 DS
Permit Expires 6/22/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Russell Oil Company 200 E. Main Galatia, IL 62935 Contact: Leon Russell (618) 926-9180</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Russell Oil Co. 7145 Rt 45 Carrier Mills, IL 62917 Contact: Kim Winters (618) 268-4722</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 7) - 6,000, (TK # 8) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 7, 8) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L*
- (d) Product to be stored in each tank: (TK # 7) - Diesel Fuel, (TK # 8) - Gasoline - Regular*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Extending vent line from existing location approximately 15-20 feet and anchoring to another wall.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Mid-South Steel Products, Inc. 2071 Corporate Circle Drive PO Box 277 Cape Girardeau, MO 63703</p>	<p>Contact Person: Billy Thorne Phone: (573) 335-5529 Contractor Registration # IL1194 Exp. 8/17/2022</p>

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File