



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 2-016794
Permit # 01218-2012UPG
Request Rec'd 11/20/2012
Amended Date
Approval Date 11/20/2012 JC
Permit Expires 5/20/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: SJK of West Chicago, Inc. 1307 S. Neltor (Route 59) West Chicago, IL 60185 Contact: Sonni Nguyen (630) 231-8580	(2) FACILITY - name and address where tanks are located: West Chicago Shell Car Wash 3107 S. Neltor (Route 59) West Chicago, Du Page Co., IL Contact: Sonni Nguyen (630) 231-8580
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 4, 5) - 12,000 gallons, (TK # 6) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 4, 5, 6) - (Installing) Dispenser Sumps containment FRP at the existing two south dispensers and at the three new southernmost dispensers, (TK # 4, 5, 6) - (Installing) partial Fiberglass Double Wall Ameron Dualoy 3000/LCX from the existing two southern dispensers to the three new southernmost dispensers.
- (d) *Product to be stored in each tank:* (TK # 4) - Bio-Diesel, (TK # 5, 6) - Gasoline
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 4, 5, 6) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the existing two southern dispenser sumps and at the three new southernmost dispenser sumps.
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 4, 5, 6) - (Installing) partial Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Lansing, IL 60438	Contact Person: Ed Angell Phone: (708) 474-3344 Contractor Registration # IL-1207 Exp.
--	--

Sincerely,

