



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2033927
Permit # 01480-2021UPG
Request Rec'd 12/21/2021
Amended Date 12/22/2021 DS
Approval Date 12/21/2021 DS
Permit Expires 6/22/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Thorntons LLC 2600 James Thornton Way Louisville, KY 40245 Contact: Maggie Seauth (502) 425-8022</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Thornton's #116 1602 Essington Rd Joliet, IL 60435 Contact: Michelle Kessler (800) 928-8022</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 3) - 12,000, (TK # 4) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 1) - Gasoline - Premium, (TK # 3) - Gasoline - Regular, (TK # 4) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices: (TK # 1, 3, 4) Overfill Prev Device - Ball Only Removed Ball Float Vent Valve, (TK # 1) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Removing existing bball only from Tank 1 Premium, Tank 3 Regular, and Tank 4 Diesel. Installing new overfill prevention valve in tank 1 Premium - existing drop tube is straight with no shutoff valve.

Amendment Reason: All tanks aside from Premium already have flapper drop tubes and i will be submitting like for like to replace those. Need to update this permit so that Premium is only tank getting new drop via permit as it has a straight tube currently, even though database is wrong. Also, need to update E85 and DSL tank 5 as ball floats have already been removed by another contractor. Need to remove new drop tubes being installed on tanks 3 and 4. These will be replaced on like for like permit since they already overfill drop tubes.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Tanknology
880 Church Road
Elgin, IL 60123

Contact Person: Jared Beavers
Phone: (847) 888-4836
Contractor Registration # IL2089 Exp. 2/18/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File