



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 7042092
Permit # 00007-2022REM
Request Rec'd 01/04/2022
Amended Date
Approval Date 1/4/2022 DS
Permit Expires 7/6/2022

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

| | |
|--|--|
| <p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Love's Travel Stops & Country Stores, Inc. P.O. Box 26210 10601 N. Penn Oklahoma City, OK 73120</p> <p>Contact: Jerrod Marsh (405) 834-0311</p> | <p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Love's Travel Stop #318 202 North Ave. Ina, IL 62846</p> <p>Contact: Jamey Fowlkes (405) 302-6640</p> |
|--|--|

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 1, 2, 3) - 20,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : IOME will open trenches from the H-box to the last set of islands at different stages. Valves will be added to the H-box manifold for isolation. The product line feeding the first set of dispensers will be removed and replaced. Once those islands are back operational then the next product line feeding the second set of islands will be removed and replaced. Once that set of islands are back operational then the last set of islands and the third and final product line will be removed and replaced. All three product lines are associated with all three diesel tanks (T-1, T-2, and T-3) All three diesel lines feeding the truck islands will be removed and replaced during the upgrade. The upgrade permit will be submitted next.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Illinois Oil Marketing Equipment, Inc.
850 Brenkman Drive
Pekin, IL 61554

Contact Person: Chris Epkins
Phone: (309) 347-1819
Contractor Registration # IL1293 Exp. 2/4/2022

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File