



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2027957
Permit # 00024-2022UPG
Request Rec'd 01/06/2022
Amended Date
Approval Date 1/6/2022 DS
Permit Expires 1/19/2022

Permit for Emergency Repair Request on 1/6/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Lehigh Gas Wholesale Services 645 Hamilton, Suite 400 Allentown, PA 18101 Contact: Jeremy Holland (610) 625-8061	(2) <u>FACILITY</u> - name and address where tanks are located: BP - IL0005 9545 191st Street Mokena, IL 60448 Contact: Nayi Kaushik (773) 716-8974
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 7) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 7) Piping - Galvanized Steel Single Wall Piping, (TK # 7) Piping - Ball Valves, (TK # 7) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 7) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replacing failed steel pipe nipple with new ball valve and flex connector.

NOTE: A sump must be installed under a separate upgrade permit if one doesn't already exist

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street


Contact Person: Ed Angell

Lansing IL 60438

Phone: (708) 474-3344

Contractor Registration # IL1207 Exp. 2/14/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File