



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Extended**

<p align="center"><b>FOR OFFICE USE ONLY</b></p> <p>Facility # 2013801 Permit # 01130-2021UPG Request Rec'd 09/29/2021 Amended Date Approval Date 9/29/2021 DS Permit Expires 9/29/2022</p>
---

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>S &amp; S Illinois Investments, LLC 12118 Somerset Dr. Orland Park, IL 60467 Contact: Shawket Samawi (952) 457-0057</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>M-3 Marathon 10 W. Golf Rd. Des Plaines, IL 60016 Contact: Shawket Samawi (847) 845-9401</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 8,000, (TK # 4) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 3, 4) Piping - Fiberglass Single Wall Piping Ameron to accomodate new dispenser sumps, (TK # 1, 2, 3, 4) Piping - Shear Valves, (TK # 1, 2, 3, 4) Piping - Flex Connector Steel, (TK # 2) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from tank to new dispenser sump, (TK # 2) Piping - Ball Valves*
- (d) Product to be stored in each tank: (TK # 1, 2) - Gasoline - Regular, (TK # 3) - Gasoline - Premium, (TK # 4) - Diesel Fuel*
- (e) Type of leak detection being used:*  
*Tank:*  
*Piping: (TK # 2) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 2) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in submersible and dispenser sumps*
- (f) Corrosion Protection being used:*  
*Tank:*  
*Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices: (TK # 2) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

**(4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


**(5) SPECIAL CONTINGENCIES :** The three West islands will be replaced to allow for new dispenser sumps to be installed. Single wall fiberglass pipe will be run from the sumps to the existing singlewall fiberglass piping for the Regular, Premium and Diesel products. A new rigid double wall fiberglass pipe will be run from the Regular tank #2 pump sump to the new dispenser sumps.

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p align="right">Contact Person: Ed Angell</p>
---

B & K Equipment Company  
2939 175th Street  
Lansing, IL 60438

Phone: (708) 474-3344  
Contractor Registration # IL1207 Exp. 2/14/2022

Sincerely,

  
\_\_\_\_\_

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File