



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 1015644  
Permit # 00051-2022REM  
Request Rec'd 01/18/2022  
Amended Date  
Approval Date 1/18/2022 DS  
Permit Expires 7/19/2022

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Lehigh Gas Wholesale Services 645 Hamilton, Suite 400 Allentown, PA 18101  Contact: Jeremy Holland (610) 625-8061</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>IL0110 342 N. Park Blvd. Freeport, IL 61032  Contact: Madison Riddell (847) 680-5831</p>
--	---

**(3) REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 2) - 8,000, (TK # 3, 4) - 6,000, (TK # 5) - 10,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 2, 3, 5) - Gasoline, (TK # 4) - Diesel Fuel*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number: 2022-0052*
- (f) *Date each tank was last used: (TK # 2, 3, 4, 5) - 8/20/2019*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Will pump out and remove all fuel from tank system down to 1-inch or less. Removal of all four (4) existing underground storage tanks, including removing dispensers, piping vents, and all containments from site per OSFM removal regulations.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Perry Environmental, Inc.  
2803 Old Rochester Road, Suite A  
Springfield, IL 62703

Contact Person: julie keebler  
Phone: (217) 523-5446  
Contractor Registration # IL002445 Exp. 4/6/2022

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File