



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2013801
Permit # 00069-2022REL
Request Rec'd 01/24/2022
Amended Date
Approval Date 1/25/2022 DS
Permit Expires 7/26/2022

Permit for INTERIOR LINING of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to internally line underground storage tank(s) or piping is hereby granted. Such interior lining must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. Such interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: S & S Illinois Investments, LLC 12118 Somerset Dr. Orland Park, IL 60467 Contact: Shawket Samawi (952) 457-0057	(2) FACILITY - name and address where tanks are located: M-3 Marathon 10 W. Golf Rd. Des Plaines, IL 60016 Contact: Shawket Samawi (847) 845-9401
---	--

(3) INTERIOR LINING OF TANKS:

- (a) Number and size of tanks being internally lined: (TK # 2) - 8,000*
 - (b) Type of tank(s):*
 - (c) Name of manufacturer of internal lining material: Bridgeport Chemical*
 - (d) Designation of internal lining material: GA 27P*
 - (e) Product to be stored in each tank: (TK # 2) - Gasoline - Regular*
 - (f) Manway accessible at grade: (TK # 2) Install*
- (4) This permit is VOID if tank is unacceptable for interior lining. Any tank that has been out of service for a twelve month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for interior lining and manway installation only. Separate permits are required to do interior tank lining inspections.
- (5) The owner must notify this Office when completion of tank internal lining has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov by calling (217)785-1020.
- (6) **SPECIAL CONTINGENCIES** : Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by section 175.500. Older Fiberglass tank. Lining for compatibility reasons. Upgrading to ethanol.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Tank Tech, Inc.
3975 State Highway H
Sikeston, MO 63801

Contact Person: Jonathan McNeely
Phone: (573) 471-1932
Contractor Registration # IL2136 Exp. 1/22/2024

Sincerely,

Daniel Starks