



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2010685
Permit # 01404-2021UPG
Request Rec'd 12/03/2021
Amended Date 01/31/2022 DS
Approval Date 12/6/2021 DS
Permit Expires 6/7/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Graham C-Stores Co. 39109 N. US Hwy 41 Wadsworth, IL 60083 Contact: John Graham (847) 223-3710	(2) <u>FACILITY</u> - name and address where tanks are located: Lake Zurich #3 1 N. Rand Road Lake Zurich, IL 60047 Contact: Lisa Railton (847) 223-3710
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 8,000, (TK # 2, 3) - 6,000, (TK # 6) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2, 3, 6) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 1, 2) - Gasoline - Regular, (TK # 3) - Diesel Fuel, (TK # 6) - Gasoline - Premium*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices: (TK # 1, 2, 3, 6) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 1, 2, 3, 6) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replacing ATG, Spill / Overfill & Stage I 4" risers with 4" Stainless Steel risers. Installing new SW Defender Spill buckets & OPW 71 SO Overfill Valves. Installing Bravo SWFRP STP Sumps w/ new bung mounts and new STP's. Added the installation of Franklin Defender SW Spill Containment manholes on the Stage I / Vent risers on eah of the (4) tanks.

Amendment Reason: Installed Spill Containment manholes on stage I risers on each of (4) tanks.


Revision Reason: Contractor did not indicate all equipment being installed/replaced

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Performance Tank, Inc.
730 Creel Drive
Wood Dale, IL 60191

Contact Person: Tim Berg
Phone: (630) 860-9500
Contractor Registration # IL881 Exp. 12/8/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File