



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6036048
Permit # 00091-2022REM
Request Rec'd 01/31/2022
Amended Date
Approval Date 1/31/2022 DS
Permit Expires 8/2/2022

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Madison County Transit One Transit Way Granite City, IL 62040</p> <p>Contact: Justin Dixon (618) 874-7433</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Madison County Transit District 724 Chain Of Rocks Road Granite City, IL 62040</p> <p>Contact: Jerry Kane (618) 874-7433</p>
--	---

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 1, 2) - 15,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Pulling out old product lines from the chase pipes associated to the tank sumps of Tank 1 and Tank 2 to the existing UDC's. Also removing product line from the secondary tank sump and UDC to the low flow dispenser connected to Tank 1. Removing low flow dispenser and installing cover plate for that UDC. Removing STP from secondary Tank 1 sump and plug entry.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Illinois Oil Marketing Equipment, Inc.
850 Brenkman Drive
Pekin, IL 61554

Contact Person: Bryan Estes
Phone: (309) 347-1819
Contractor Registration # IL1293 Exp. 2/4/2022

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File