



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

REVISED

FOR OFFICE USE ONLY

Facility # 3-008580
Permit # 01427-2007UPG
Request Rec'd 09/06/2007
Amended Date
Approval Date 9/7/2007 JC
Permit Expires 3/7/2008

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Aman Food & Gas 1830 5th Ave. Moline, IL 61265 Contact: Jeet Singh 309-764-5501	(2) FACILITY - name and address where tanks are located: Aman Food & Gas 1830 5th Avenue Moline, Rock Island Co., IL Contact: Jeet Singh (309) 764-5501
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 1) - 5,000 gallons, (TK # 2) - 3,000 gallons, (TK # 3) - 4,000 gallons
- (b) **Type of tanks:** (TK # 1, 2, 3) - Existing single wall steel
- (c) **Type of piping:** (TK # 1, 2) - (Installing) Ameron double wall fiberglass for the new syphon line between tanks 1 & 2, (TK # 1, 2, 3) - Existing double wall fiberglass (the existing product piping run for tank #2 will be abandoned in place through a separate permit - the piping is within the same piping trench for tanks 1 & 3).
- (d) **Product to be stored in each tank:** (TK # 1, 2, 3) - Gasoline
- (e) **Type of leak detection being used:**
Tank: (TK # 1, 2, 3) - Existing automatic tank gauging
Piping: (TK # 1, 3) - Existing line leak detector to remain (the line leak detector for tank #2 will be removed), (TK # 1, 3) - Existing interstitial monitoring to remain at the submersible sumps only (the existing sensor for tank #2 will be removed)
- (f) **Corrosion Protection being used:**
Tank: (TK # 1, 2, 3) - Existing interior lining
Piping: (TK # 1, 2, 3) - Existing fiberglass
- (g) **Spill containment devices:** (TK # 1, 2, 3) - Existing spill containment manhole
- (h) **Overfill prevention devices:** (TK # 1, 2, 3) - Existing drop tube valve
- (i) **Manway accessible at grade:**

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** The latest revision is to reflect the new owner information. **Revision is to reflect the fact that the product line for tank #2 will be abandoned, not the line for tank #1.** The tops of the tanks being siphoned together must be within 6" elevation of each other. **The product line for tank #2 will be abandoned in place through an abandonment permit that will be applied for (according to contractor, the piping is all in the same piping trench as the other active lines).** There will also be two dispensers replaced at the existing islands.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Art Wentworth Phone: Contractor Registration # Exp.

Sincerely,

James J. Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)