



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-043775
Permit # 01379-2007INS
Request Rec'd 08/23/2007
Amended Date
Approval Date 8/31/2007 JC
Permit Expires 2/29/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Gas City, Ltd. 160 S. LaGrange Road Frankfort, IL 60423 Contact: Len McEnergy (815) 469-9000	(2) FACILITY - name and address where tanks are located: Gas City #957 570 Laraway New Lenox, Will Co., IL Contact:
--	--

(3) INSTALLATION OF TANKS:

- (a) **Number and size of tanks being installed:** (TK # 1) - 20,000 gallons, (TK # 2) - 8,000 gallons, (TK # 3, 4) - 3,000 gallons, (TK # 5) - 6,000 gallons, (TK # 6) - 12,000 gallons
- (b) **Type of tanks:** (TK # 1, 2, 3, 4, 5, 6) - (Installing) Glasteel II double wall composite
- (c) **Type of piping:** (TK # 1, 2, 3, 4, 5, 6) - (Installing) Environ Geo Flex flexible double wall
- (d) **Product to be stored in each tank:** (TK # 1, 6) - Gasoline, (TK # 2) - Diesel Fuel, (TK # 3) - Kerosene, (TK # 4) - Racing Fuel, (TK # 5) - E-85
- (e) **Type of leak detection being used:**
 - Tank:** (TK # 1, 2, 3, 4, 5, 6) - (Installing) Veeder Root TLS 350 interstitial tank sensor, (TK # 1, 2, 3, 4, 5, 6) - (Installing) Veeder Root TLS350 automatic tank gauge
 - Piping:** (TK # 1, 2, 3, 4, 5, 6) - (Installing) Veeder Root TLS350 electronic line leak detector, (TK # 1, 2, 3, 4, 5, 6) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at all dispenser sumps and all submersible sumps.
- (f) **Corrosion Protection being used:**
 - Tank:** (TK # 1, 2, 3, 4, 5, 6) - (Installing) Composite
 - Piping:** (TK # 1, 2, 3, 4, 5, 6) - (Installing) Non-corrosive flexible
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Contact Person: Mark Romiti Phone: Contractor Registration # Exp.
--

Sincerely,

