



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 2-034834  
Permit # 01378-2007INS  
Request Rec'd 08/30/2007  
Amended Date  
Approval Date 8/31/2007 JC  
Permit Expires 2/29/2008

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|                                                                                                                                                                                                      |                                                                                                                                                                                      |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:<br><br>Delnor Community Hospital<br>300 Randall Rd<br>Geneva, IL 60134<br><br>Contact: Dave KelpsWolf (630) 208-4271 | <b>(2) FACILITY</b> - name and address where tanks are located:<br><br>Delnor Community Hospital<br>300 Randall Rd<br>Geneva, Kane Co., IL<br><br>Contact: Dave Kelps (630) 208-4271 |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**(3) INSTALLATION OF TANKS:**

- (a) **Number and size of tanks being installed:** (TK # 2) - 20,000 gallons
- (b) **Type of tanks:** (TK # 2) - (Installing) Glasteel II double wall composite
- (c) **Type of piping:** (TK # 2) - (Installing) A.P.T. Poly Tech P100SC double wall flexible, (TK # 2) - (Installing) A.P.T. Poly Tech DCT-400 secondary chase piping.
- (d) **Product to be stored in each tank:** (TK # 2) - Diesel Fuel
- (e) **Type of leak detection being used:**  
**Tank:** (TK # 2) - (Installing) Veeder Root TLS 350 Plus Automatic tank gauge with CSLD, (TK # 2) - (Installing) Veeder Root TLS 350 Plus Interstitial tank sensor  
**Piping:** (TK # 2) - (Installing) Veeder Root TLS 350 Plus interstitial piping sump sensors at tank sump and at the piping junction sump, (TK # 2) - (Installing) American Suction
- (f) **Corrosion Protection being used:**  
**Tank:** (TK # 2) - (Installing) Composite  
**Piping:** (TK # 2) - (Installing) Non-corrosive flexible
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

**(5) GENERAL REQUIREMENTS:**

**(6) SPECIAL CONTINGENCIES:**

|                                                                                                                                                                          |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b><br><br><br><br><br><br><br><br><br><br>Contact Person: Jan<br>Phone:<br><br>Contractor Registration #    Exp. |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

Sincerely,

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 1/98)