



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3003309
Permit # 00229-2022UPG
Request Rec'd 03/08/2022
Amended Date
Approval Date 3/8/2022 DS
Permit Expires 9/8/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: County of Rock Island 1504 3rd Avenue Rock Island, IL 61201 Contact: April Palmer (309) 786-4451	(2) FACILITY - name and address where tanks are located: Rock Island County Public Works Department 851 W. 10th Ave. Milan, IL 61264 Contact: Donna Huys (309) 787-4668
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 4) - 2,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 4) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC from existing tank to new dispenser island in the same location as previous island as shown in site drawing, (TK # 4) Piping - Other Steel Riser, (TK # 4) Piping - Other Submersible Pump, (TK # 4) Piping - Ball Valves, (TK # 4) Piping - Shear Valves, (TK # 4) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 4) - Gasoline - Regular*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 4) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 4) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in submersible and dispenser sumps*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices: (TK # 4) Spill Contain Device - Double Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 4) Overfill Prev Device - Overfill Drop Tube Valve, (TK # 4) Overfill Prev Device - Overfill Alarm*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Installation of new island, udc and stp sump. Installation of new d/w APT piping. Island will be placed in the same place as existing. Vent line is to be re-used.

Replaced piping exceeds 20 feet or 50% of the total pipe run.

NOTE: Piping being replaced is being removed under permit 01440-2021REM

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Contact Person: Glen Davis
Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2024

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File