



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2016446
Permit # 00261-2022UPG
Request Rec'd 03/15/2022
Amended Date
Approval Date 3/15/2022 DS
Permit Expires 9/15/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Sukun Estates, LLC 2135 N. Greenbay Rd. Waukegan, IL 60087 Contact: Fehmida Valiullah (847) 989-1516</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Citgo Gas Station 2135 North Green Bay Road Waukegan, IL 60087 Contact: Fehmida Valiullah (847) 732-0331</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 8) - 10,000, (TK # 9, 10) - 5,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 8, 9, 10) Piping - PARTIAL Flexible Double Wall Ameron FLX-3000 w/fip secondary to accomodate new dispenser sump , (TK # 8, 9, 10) Piping - Shear Valves , (TK # 8, 9, 10) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 8) - Gasoline - Regular, (TK # 9) - Diesel Fuel, (TK # 10) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Dispenser was struck by vehicle. Sawcut and breakout around dispenser island #1/2 to expose existing piping. Install new dispenser containment sump. Install new double wall flexible fiberglass piping (3 over 2) connected to the existing piping. Pour new island. Install new dispenser.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: (708) 474-3344

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File