



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 4015331  
Permit # 00280-2022REM  
Request Rec'd 03/17/2022  
Amended Date  
Approval Date 3/21/2022 DS  
Permit Expires 9/21/2022

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>IL Central Management Services 401 S. Spring Street, Rom 721 Springfield, IL 627064100</p> <p>Contact: Rick Tate (217) 558-6587</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Dwight Correctional Center 23813 East 3200 North Road Dwight, IL 60420</p> <p>Contact: Rick Tate (217) 558-6587</p>
--	--

(3) **REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 4) - 2,500*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 4) - Gasoline*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 4) - 3/1/2013*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES :**

Any water/product will be pumped out of the tank and the owner will have it hauled off to a treatment facility. The tank will then be freed of vapor to eliminate the explosion/fire potential. After the atmosphere in the tanks are rendered safe, and with the Fire Marshal's approval, the tank will then be removed from the ground. The tank will be cut and cleaned and then sent for disposal. The excavation will be backfilled to grade with crushed aggregate or other suitable clean backfill.

CSD Environmental Services, Inc. personnel will be onsite to provide removal oversight and documentation including soil samples. Samples will consist of (4) sidewall samples and (2) floor samples and be tested for BTEX and MTBE, lead and pH based upon the determination the tank contained gasoline (in accordance with 35 Ill. Adm. Code 734). Removal efforts will be summarized in a site assessment report to be supplied to the OSFM upon completion. Photos of the removal activities as well as a site map showing sample locations will be included with the report.

**NOTE: Any associated piping must be removed as well**

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

CSD Environmental Services, Inc.  
2220 Yale Boulevard  
Springfield, IL 62703

Contact Person: Frank Pinkley  
Phone: (217) 522-4085  
Contractor Registration # IL002230 Exp. 3/17/2024

Sincerely,

*Daniel G. Starks*

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File