



Office of the Illinois State Fire Marshal  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 2177851020

**FOR OFFICE USE ONLY**  
 Facility # 2028792  
 Permit # 00313-2022UPG  
 Request Rec'd 03/25/2022  
 Amended Date  
 Approval Date 3/28/2022 DS  
 Permit Expires 4/8/2022

**Permit for Emergency Repair Request on 3/24/2022**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Lehigh Gas Wholesale Services          645 Hamilton, Suite 400          Allentown, PA 18101          Contact: Thomas Roy (610) 625-8061</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>IL0126          5201 W. 111th St.          Alsip, IL 60803          Contact: R G Schumann (847) 680-5831</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 2) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 2) - Gasoline - Regular*
- (e) *Type of leak detection being used:*  
     *Tank:*  
     *Piping:*
- (f) *Corrosion Protection being used:*  
     *Tank:*  
     *Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Replacing Flex connector in RUL slave tank

**NOTE: A sump must be installed under a separate permit if one doesn't already exist**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>America Petropump Services LLC d/b/a Ampsco Services          4075 Fox Valley Center Dr., Unit 9          Aurora, IL 60504</p>	<p>Contact Person: Ravindra Penmatsa          Phone: (312) 286-6722          Contractor Registration # IL002420 Exp. 5/22/2023</p>

Sincerely,

*Daniel H. Starks*

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File