



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 3035590  
Permit # 00322-2022UPG  
Request Rec'd 03/24/2022  
Amended Date  
Approval Date 3/29/2022 DS  
Permit Expires 9/29/2022

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Rameshwaram, LLC 365 US 6 E Geneseo, IL 61254 Contact: Chetankumar Patel (330) 979-2110</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Homecity Express 365 US Hwy 6 East Geneseo, IL 61254 Contact: Dhaval Vakharia (309) 979-2110</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 5) - 4,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 5) Piping - Flexible Double Wall A.P.T. Poly Tech S150SC from existing tank to new dispenser sump/dispenser as shown in drawing*
- (d) Product to be stored in each tank: (TK # 5) - E-85*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 5) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Remove old piping for the E85 product.

Add new APTXP150 1 1/2" Doublewall pipe, New Gilbarco E85 dispenser, new FE petro AG 3/4hp sub pump. Reuse tank sump add new entry boots, add sump sensor. Also install new dispenser sump with sump sensor.

Replaced piping exceeds 20 feet or 50% of the total pipe run.


**NOTE: A piping removal permit must be obtained**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Pipeco, Inc.  
610 29TH ST  
Bettendorf, IA 52722

Contact Person: Debbie Rindler  
Phone: (563) 344-0700  
Contractor Registration # IL2034 Exp. 9/28/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File