



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4024245
Permit # 00331-2022UPG
Request Rec'd 03/17/2022
Amended Date
Approval Date 3/31/2022 DS
Permit Expires 9/30/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Dewitt County 201 W. Wshington Clinton, IL 61727</p> <p>Contact: Dee Dee Rent Meister (217) 935-5917</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Clinton Lake Marina 6599 Sail Boat Road Weldon, IL 61882</p> <p>Contact: Greg Forrest (217) 736-2727</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1) Piping - Flexible Double Wall A.P.T. Poly Tech MarinaFlex metallic ducted, (TK # 1) Piping - Shear Valves, (TK # 1) Piping - Single Wall Transition Sump*
- (d) Product to be stored in each tank: (TK # 1) - Gasoline - Regular*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 1) Leak Detect - Piping - Non-Discriminating Sump Sensor*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Install new marine APT double wall pipe from dock sump to new transition sump. Install new Double wall Marine pipe to both single wall UDC sumps. Install new shear valves. Install new sump sensors in all four sumps.

Replaced piping exceeds 20 feet or 50% of the total pipe run.


(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: William "Butch" VonDrehle

Pemco Service Company, Inc.
1040 East Second Street
Gilman, IL 60938

Phone: (815) 265-7364
Contractor Registration # IL1224 Exp. 2/26/2024

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File