



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**  
Facility # 1008456  
Permit # 00361-2022UPG  
Request Rec'd 04/06/2022  
Amended Date  
Approval Date 4/6/2022 DS  
Permit Expires 10/6/2022

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Carroll Service Company 505 West Illinois Route 64 Lanark, IL 61046</p> <p>Contact: chris markley (815) 493-2181</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Carroll Service Company 505 West Illinois Route 64 Lanark, IL 61046</p> <p>Contact: Chris Markley (815) 493-2181</p>
------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 3) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 3) Piping - Flexible Double Wall A.P.T. Poly Tech*
- (d) *Product to be stored in each tank: (TK # 3) - Diesel Fuel*
- (e) *Type of leak detection being used:*  
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*  
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


**(5) SPECIAL CONTINGENCIES :**

Existing canopy and dispenser to remain. We are moving the satellite island over 3 feet to allow for better access. We will bust out inbetween existing master and satellite, move the satellite 3' further from the master and install a new section of 1.5" apt pipe between the islands.

**NOTES: UDCs are required to be installed if not already existing along with sump sensors with positive shutdown**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>Oil Equipment Company, Inc. 4701 Lien Road Madison, WI 53704</p>	<p>Contact Person: TJ Winkler Phone: (608) 249-2881 Contractor Registration # IL1318 Exp. 11/13/2022</p>

Sincerely,



---

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File