



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 6-024449
Permit # 01361-2007TUP
Request Rec'd 08/28/2007
Amended Date
Approval Date 8/28/2007 JC
Permit Expires 2/28/2008

**Permit for TOUCH-UP INTERIOR LINING of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to internally line underground storage tank(s) or piping is hereby granted. Such partial interior lining must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. Such partial interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Gateway FS, Inc.        221 E. Pine Street, P.O. Box 100        Red Bud, IL 62278</p> <p>Contact: Jeff Gillespie (618) 282-4000</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Gateway Fs Inc        509-511 Park St        Waterloo, Monroe Co., IL</p> <p>Contact: Smith Cathy (618) 939-4979</p>
---	--

**(3) INTERIOR LINING OF TANKS:**

- (a) *Number and size of tanks being internally lined:* (TK # 4) - 5,000 gallons, (TK # 5, 6) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Name of manufacturer of internal lining material:* (TK # 4, 5, 6) Armor Shield
- (d) *Designation of internal lining material:* (TK # 4, 5, 6) TL 300M
- (e) *Product to be stored in each tank:* (TK # 4) - E-85, (TK # 5, 6) - Gasoline  
 (Internal lining material must be compatible with product stored in each tank)
- (f) *Percentage of each tank being partially lined:* Tank #4 - 3% / Tank #5 - 3% / Tank #6 - 3%.  
 (Lining Touch-up cannot exceed 30% of entire tank)

- (4) **This permit is VOID if tank is unacceptable for touch-up of interior lining. Any tank that has been out of service for a twelve month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for touch-up of interior lining only. Separate permits are required to do interior tank lining inspections or installations of manways.**
- (5) **The owner must notify this Office when completion of tank internal lining touch-up has occurred, on the Notification Form for Underground Storage Tank Form. This form can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**
- (6) **SPECIAL CONTINGENCIES:** Contractor states there are existing manways. The underground storage tank system for tank #4 must be compatible with E-85, as indicated in section 170.470, 170.500, 170.530(d)(2), 170.530(j), and 170.540(a) of Title 41 of the Illinois Administrative Code, and as indicated in policy #06-PCS-005 regarding the use of alternative fuels in underground storage tanks.

<b>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>Superior Equipment Co Inc        3283 Ivanhoe Ave</p>	<p>Contact Person: Greg        Phone:        Contractor Registration #    Exp.</p>

Sincerely,

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 1/98)