



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2007980
Permit # 00400-2022UPG
Request Rec'd 04/16/2022
Amended Date
Approval Date 4/17/2022 DS
Permit Expires 10/18/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: HPT TA Properties, LLC 24601 Center Ridge Road Westlake, OH 44145 Contact: Bonnie Parrino (440) 808-7268	(2) FACILITY - name and address where tanks are located: Travel Centers of America 19 N 430 Rte. 20 Hampshire, IL 60140 Contact: Marc Miles (440) 683-4550
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 3, 4, 5) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 3, 4, 5) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 4, 5) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 3, 4, 5) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Installing LCX pipe from the east diesel dispenser to gasoline dispensers 3/4 & 5/6. Installing new Bravo dispenser sumps at dispensers 3/4 & 5/6. Replaced piping exceeds 20 feet or 50% of the total pipe run.

NOTES: Piping removal permit must be obtained. Sump sensors with positive shut down must be installed in sumps associated with piping upgrade per section 175.640 a) 1) of our rules

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company

Contact Person: Warren Cherner
Phone: (847) 465-4000

1111 West Dundee Road
Wheeling, IL 600903936

Contractor Registration # IL102 Exp. 2/7/2024

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File