



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2012963  
Permit # 00402-2022UPG  
Request Rec'd 04/14/2022  
Amended Date  
Approval Date 4/18/2022 DS  
Permit Expires 10/18/2022

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Graham C-Stores Co. 39109 N. US Hwy 41 Wadsworth, IL 60083  Contact: John Graham (847) 223-3710	<b>(2) FACILITY</b> - name and address where tanks are located:  Wonder Lake #111 7517 Hancock Rd. Wonder Lake, IL 60097  Contact: Roderick Anderson (847) 223-3710 Ext. 16
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5, 6, 8, 9) - 5,000, (TK # 7) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 5, 6, 7, 8, 9) Piping - Flexible Double Wall NUPI Smartflex from existing tanks to new dispensers as shown in site plan, (TK # 5, 6, 7, 8, 9) Piping - Other Steel Riser, (TK # 5, 7, 8, 9) Piping - Other Submersible Pump, (TK # 5, 6, 7, 8, 9) Piping - Single Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 5) - Diesel Fuel, (TK # 6) - Kerosene, (TK # 7, 9) - Gasoline - Regular, (TK # 8) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 5, 6, 7, 8, 9) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in submersible and dispenser sumps, (TK # 6) Leak Detect - Piping - European with No Test Req Suction*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 5, 6, 7, 8, 9) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 5, 6, 7, 8, 9) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

The existing tanks are to remain. The existing Veeder Root equipment will remain. We will be replacing all tank top steel risers with new stainless steel risers. We will be installing new SW Defender Spill buckets w/ OPW 71 SO series Overfill valves. Installing SW STP and Dispenser sumps with new Nupi DW Smartflex piping to (6) new dispenser islands.


Replaced piping exceeds 20 feet or 50% of the total pipe run.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Performance Tank, Inc.  
730 Creel Drive  
Wood Dale, IL 60191

Contact Person: Tim Berg  
Phone: (630) 860-9500  
Contractor Registration # IL881 Exp. 12/8/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File