



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2010011
Permit # 00455-2022REM
Request Rec'd 04/28/2022
Amended Date
Approval Date 4/28/2022 DS
Permit Expires 10/28/2022

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>2441 Franklin, LLC 1983 Route 52 Hopewell Junction, NY 12533</p> <p>Contact: Patty Garcia (845) 765-8507</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>2441 Franklin, LLC 2441 North Mannheim Road Franklin Park, IL 60131</p> <p>Contact: Syed Kirmani (845) 765-8507</p>
---	--

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 6) - 15,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

- (4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

- (5) **SPECIAL CONTINGENCIES** : Remove product line between diesel master dispenser 1 & satellite dispenser 1, total length 13'.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: (708) 474-3344
Contractor Registration # IL1207 Exp. 12/17/2023

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File