



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4008001
Permit # 00456-2022REM
Request Rec'd 04/28/2022
Amended Date
Approval Date 4/28/2022 DS
Permit Expires 10/28/2022

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>GPM Gas Mart Realty Co., LLC 8565 Magellan Pkwy, Ste. 400 Richmond, VA 23227</p> <p>Contact: Rolfe Lann (804) 730-1568</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Fas Mart #560 309 Spring Creek Rd. Montrose, IL 62443</p> <p>Contact: Ashley Hammond (804) 730-1568 Ext. 1208</p>
---	--

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 3) - 4,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES :**

Remove old abandoned Diesel lines between island and plug off diesel lines going to tank. As per Travis Smith.

We submitted an upgrade permit to replaced all UDC's and the diesel lines were abandoned inside the UDC's and that's why we are removing them.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Pemco Service Company, Inc.
1040 East Second Street
Gilman, IL 60938

Contact Person: William "Butch" VonDrehle
Phone: (815) 265-7364
Contractor Registration # IL1224 Exp. 2/26/2024

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File