



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1024669
Permit # 00470-2022UPG
Request Rec'd 05/02/2022
Amended Date
Approval Date 5/2/2022 DS
Permit Expires 11/2/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Johnson Oil Company 1305 12th Avenue Rock Falls, IL 61071 Contact: Kathy Peugh (815) 625-6380	(2) <u>FACILITY</u> - name and address where tanks are located: Sheridan Amoco Food Shop 200 W. S. Johnson Ave. Sheridan, IL 60551 Contact: Tracy Shoopman (815) 496-9266
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 8,000, (TK # 2) - 6,000, (TK # 3) - 4,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 1, 2) - Gasoline - Regular, (TK # 3) - Gasoline - Premium*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices: (TK # 1, 2, 3) Overfill Prev Device - Overfill Alarm*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : The Current overfill prevention drop tubes will be removed and an Alarm console installed on the exterior of the building. All tanks.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illowa Enterprises, Inc.
2703 4th Avenue
Moline, IL 61265

Contact Person: James Saddoris
Phone: (309) 762-1729
Contractor Registration # IL981 Exp. 5/1/2024

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File