



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2047413
Permit # 00478-2022INS
Request Rec'd 04/29/2022
Amended Date
Approval Date 5/4/2022 DS
Permit Expires 11/4/2022

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Love's Travel Stops & Country Stores, Inc. P.O. Box 26210 10601 N. Penn Oklahoma City, OK 73120 Contact: Jerrod Marsh (405) 834-0311	(2) FACILITY - name and address where tanks are located: Love's Travel Stops #859 8909 N. Brisbin Rd Morris, IL 60450 Contact: Kyle Collins (405) 834-0311
--	---

(3) INSTALLATION OF TANKS:

- (a) *Number and size of tanks being installed: (TK # 1, 6) - 20,000, (TK # 2) - 12,000, (TK # 3, 8, 12) - 8,000, (TK # 4, 5) - 30,000, (TK # 7, 9, 10, 11) - 3,000, (TK # 13) - 7,000*
- (b) *Type of tank(s): (TK # 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13) Tank - Fiberglass Double Wall*
- (c) *Type of piping: (TK # 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13) Piping - Flexible Single Wall Piping for vents, (TK # 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13) Piping - Flexible Double Wall Franklin Fueling Systems UPP from tanks to dispensers and transtion sumps for fueling and from tanks to transtion sump at building for motor oil tanks, (TK # 1, 2, 3, 4, 5, 6) Piping - Other Steel Riser, (TK # 1, 2, 3, 4, 5, 6) Piping - Other Submersible Pump, (TK # 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13) Piping - Ball Valves , (TK # 1, 2, 3, 4, 5, 6) Piping - Shear Valves , (TK # 1, 2, 3, 4, 5, 6) Piping - Flex Connector Steel, (TK # 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13) Piping - Single Wall STP/Tanktop Sump , (TK # 1, 2, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13) Piping - Single Wall Transition Sump*
- (d) *Product to be stored in each tank: (TK # 1, 2) - Gasoline - Regular, (TK # 3) - Gasoline - Premium, (TK # 4, 5) - Diesel Fuel, (TK # 6) - B-99, (TK # 7, 8, 9, 10, 11, 12) - Motor Oil, (TK # 13) - Used Oil*
- (e) *Type of leak detection being used:*

Tank: (TK # 1, 2, 3, 4, 5, 6) Leak Detect - Tank - Automatic Tank Gauging Incon EVO 5000 , (TK # 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13) Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors , (TK # 7, 8, 9, 10, 11, 12, 13) Leak Detect - Tank - Automatic Tank Gauging Incon TS 550

Piping: (TK # 1, 2, 3, 4, 5, 6) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in submersible and dispenser sumps as well as in transition sumps also in remote fill sumps, (TK # 1, 2, 3, 4, 5, 6) Leak Detect - Piping - Siphon Bar , (TK # 7, 8, 9, 10, 11, 12, 13) Leak Detect - Piping - European with No Test Req Suction , (TK # 7, 8, 9, 10, 11, 12, 13) Leak Detect - Piping - Piping Sump Sensors Not Regulated in motor oil and used oil sumps
- (f) *Corrosion Protection being used:*

Tank: (TK # 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13) Corrosion Prot - Tank - Fiberglass Non-Corrosive

Piping: (TK # 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13) Corrosion Prot - Piping - Flexible Non-Corrosive
- (g) *Spill containment devices, piping and dispenser containment devices: (TK # 1, 2, 3, 4, 5, 6, 13) Spill Contain Device - Single Wall Spill Bucket , (TK # 7, 8, 9, 10, 11, 12, 13) Spill Contain Device - Single Wall Spill Bucket Horizontal Cabinet*
- (h) *Overfill prevention devices: (TK # 1, 2, 3, 4, 5, 6) Overfill Prev Device - Overfill Drop Tube Valve , (TK # 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13) Overfill Prev Device - Overfill Alarm*

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov by calling (217)785-1020.


- (5) **GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.
- (6) **SPECIAL CONTINGENCIES** : NOTES: Please see attached scope of work. A motor fuel dispensing app must be submitted asap

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illinois Oil Marketing Equipment, Inc.
850 Brenkman Drive
Pekin, IL 61554

Contact Person: Bryan Estes
Phone: (309) 347-1819
Contractor Registration # IL1293 Exp. 2/4/2024

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File