



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY  
Facility # 2-032549  
Permit # 01187-2012UPG  
Request Rec'd 11/08/2012  
Amended Date  
Approval Date 11/14/2012 JC  
Permit Expires 5/14/2013

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: HPT TA Properties, LLC 24601 Center Ridge Road Westlake, OH 44145 Contact: Kenny Kucker (309) 827-4676	<b>(2) FACILITY</b> - name and address where tanks are located: Travel Center of America #030 16650 Russell Road Russell, Lake Co., IL Contact: Sam Hammad (847) 395-5580
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 1, 2, 3, 4, 5) - 20,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:** (TK # 1, 2, 3, 4, 5) - (Installing) partial 3" Fiberglass Double Wall Ameron Dualoy 3000/LCX for two new siphon bars between these tanks as per site plan (the existing siphon bar will be removed by a separate pending removal permit - see contingencies section and prior site plan from permit #01994-2008UPG for reference), (TK # 1, 2, 3, 4, 5) - (Installing) tank Sumps containment FRP at the tanks to accommodate the new siphon bars.
- (d) **Product to be stored in each tank:** (TK # 1, 2, 3, 4, 5) - Diesel Fuel
- (e) **Type of leak detection being used:**  
**Tank:** The existing tank gauge probes will be re-used / relocated in different existing bungs on each of these tanks.  
**Piping:** The existing submersible / tank sump sensors will be re-used / relocated in the new / relocated tank sumps.
- (f) **Corrosion Protection being used:**  
**Tank:**  
**Piping:** (TK # 1, 2, 3, 4, 5) - (Installing) partial Fiberglass Non-Corrosive
- (g) **Spill containment devices, piping, and dispenser containment devices:**
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Mokena, IL 60448	Contact Person: Hoyt Ary Phone: (708) 478-6190 Ext. 231  Contractor Registration # IL-002275 Exp.
---	--

Sincerely,

