



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
3127453162

Amended

FOR OFFICE USE ONLY

Facility # 2008464
Permit # 01409-2021INS
Request Rec'd 12/02/2021
Amended Date 05/13/2022 Chi
Approval Date 12/6/2021
Permit Expires 6/7/2022

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Kamaram Moten 4900 W. Fullerton Chicago, IL 60639 Contact: IMRAN MOTEN (773) 889-6562	(2) FACILITY - name and address where tanks are located: Suha Fullerton Citgo 4900 W. Fullerton Chicago, IL 60639 Contact: Imran Moten (773) 889-6562
---	--

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 9) - 4,000, (TK # 10) - 8,000*
- (b) Type of tank(s): (TK # 9, 10) Tank - Fiberglass Double Wall XERXES*
- (c) Type of piping: (TK # 9, 10) Piping - Flexible Double Wall NUPI Smartflex, (TK # 9, 10) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 9) - E-85, (TK # 10) - Gasoline - Premium*
- (e) Type of leak detection being used:*
 - Tank: (TK # 9, 10) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD, (TK # 9, 10) Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors*
 - Piping: (TK # 9, 10) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 9, 10) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown*
- (f) Corrosion Protection being used:*
 - Tank: (TK # 9, 10) Corrosion Prot - Tank - Fiberglass Non-Corrosive*
 - Piping: (TK # 9, 10) Corrosion Prot - Piping - Flexible Non-Corrosive*
- (g) Spill containment devices, piping and dispenser containment devices: (TK # 9, 10) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 9, 10) Overfill Prev Device - Overfill Drop Tube Valve*

- (4)** The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.
- (6) SPECIAL CONTINGENCIES** :
Amendment Reason: LINE LEAK DETECTION TYPE CHANGE. MECHANICAL TO ELECTRONIC

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Cardinal Compliance LLC
730 Creel Dr
Wood Dale, IL 601910000

Contact Person: Chris Derro
Phone: (708) 452-8620
Contractor Registration # IL002418 Exp. 3/18/2023

Sincerely,


Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File