



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2047419
Permit # 00513-2022REM
Request Rec'd 05/16/2022
Amended Date
Approval Date 5/16/2022 DS
Permit Expires 11/16/2022

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Forest Preserve District of Kane County 1996 South Kirk Road, Suite 320 Geneva, IL 60134 Contact: (630) 232-5980	(2) <u>FACILITY</u> - name and address where tanks are located: Schweitzer Woods Forest Preserve 16N900 Sleepy Hollow Road West Dundee, IL 60118 Contact: Jenny Estes (630) 768-0016
--	--

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed: (TK # 1, 2, 3) - 500*
- (b) Description/location of piping being removed:*
- (c) Product to be stored in each tank: (TK # 1, 2, 3) - Heating Oil*
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used: (TK # 1, 2, 3) - 12/31/1973*

- (4)** The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

Excavation and removal of three (3) 500-gallon capacity heating oil tanks:

Notify utility companies to locate underground lines.
Mobilize manpower and equipment to the site
Excavate and remove 3-550 gallon underground storage tanks.
Open ends of the steel tanks and clean tanks interiors.
Remove all associated underground vent and product piping.
Haul and dispose of tank and furnish certificate of tanks destruction.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

RW Collins Company
7225 West 66th Street
Chicago, IL 60638

Contact Person: Lisa Kruse
Phone: (708) 458-6868
Contractor Registration # IL772 Exp. 2/9/2024

Sincerely,

Daniel Starks

