



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3035590
Permit # 00517-2022REM
Request Rec'd 05/16/2022
Amended Date
Approval Date 5/16/2022 DS
Permit Expires 11/16/2022

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Rameshwaram, LLC 365 US 6 E Geneseo, IL 61254</p> <p>Contact: Chetankumar Patel (330) 979-2110</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Homecity Express 365 US Hwy 6 East Geneseo, IL 61254</p> <p>Contact: Dhaval Vakharia (309) 979-2110</p>
---	--

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 5) - 4,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

- (4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES :**

We will be removing the old E85 Line and installing a new APT1.5xp Double wall Flexible pipe. Installing new AG Subpump, single wall containments, and sensors in all sumps. also installing a ne Gilbarco Encore 700 NAO dispenser.

NOTES: Only the piping can be removed under this permit, all other work will need to be done under a separate upgrade application. A blended fuel compatibility form must be submitted with the upgrade permit.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Pipeco, Inc.
610 29TH ST
Bettendorf, IA 52722

Contact Person: Debbie Rindler
Phone: (563) 344-0700
Contractor Registration # IL2034 Exp. 9/28/2022

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File