



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2021203  
Permit # 00520-2022UPG  
Request Rec'd 05/17/2022  
Amended Date  
Approval Date 5/17/2022 DS  
Permit Expires 11/17/2022

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  RDK Ventures, LLC 550 Warrenville Rd., Suite 400 Lisle, IL 60532  Contact: Elizabeth Patterson (630) 800-6065	<b>(2) FACILITY</b> - name and address where tanks are located:  Circle K #6805 1301 Half Day Road Deerfield, IL 60015  Contact: John Kyle (812) 379-9227
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 3) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 3) Piping - Fiberglass Single Wall Piping Ameron , (TK # 1, 3) Piping - Shear Valves , (TK # 1, 3) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 3) - Gasoline - Premium*
- (e) *Type of leak detection being used:*  
  
*Tank:*  
  
*Piping:*
- (f) *Corrosion Protection being used:*  
  
*Tank:*  
  
*Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES** : Break out island and remove dispenser pan. Cut back lines 5 feet and install a new UDC. Extend lines back into new sump, hydro test sump, install new shears and flex connectors. Have Tanknology test lines, set dispenser and put back into operation.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Anderson Pump Service, Inc.  
19659 South 97th Avenue  
Mokena, IL 60448

Contact Person: Ronald Anderson  
Phone: (708) 478-6190  
Contractor Registration # IL002275 Exp. 5/21/2022

Sincerely,

*Daniel G. Starks*

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File