



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6021649
Permit # 00537-2022UPG
Request Rec'd 05/19/2022
Amended Date
Approval Date 5/19/2022 DS
Permit Expires 11/21/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: BKB Fuels, Inc. P.O. Box 1263 Bloomington, IL 61702 Contact: Hardeep Bhalla (630) 673-7625	(2) FACILITY - name and address where tanks are located: BKB Fuels, Inc. 409 East Missouri Sandoval, IL 62882 Contact: Hardeep Bhalla (630) 673-7625
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 3, 4) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 3, 4) Piping - Ball Valves , (TK # 3, 4) Piping - Flex Connector Steel, (TK # 3, 4) Piping - Single Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 3) - Gasoline - Premium, (TK # 4) - Gasoline - Regular*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 3, 4) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : 4. Disconnect pipe from unleaded and premium STP units. 5. Remove existing STPs and sump sensors and set aside for reinstallation. 6. Saw cut and demo approximately 20' x 25' to expose unleaded and premium STP manholes, spill buckets, and two (2) adjacent 18" manholes. Properly dispose of all excavated material. 7. Remove backfill and pull back existing piping and electric and remove sump from tank top. 8. Furnish and install two (2) 4" tank fitting adaptors to bottom of new sump. 9. Furnish and install two (2) OPW fiberglass STP sumps to unleaded tank. 10.. Furnish and install two (2) 1.5" rigid entry fitting and four (4) 3/4" conduit rigid entry fittings. One (1) 1.5" and two (2) 3/4" fittings to each sump. 11. Furnish and install two (2) OPW Edge single wall spill buckets. Paint one (1) lid white and the other red. 12. Furnish and install four (4) OPW 18" manhole. 13. Complete a line test on the unleaded and premium tanks and water test new sumps.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2024

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File