



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 7025619
Permit # 00543-2022UPG
Request Rec'd 05/20/2022
Amended Date
Approval Date 5/23/2022 DS
Permit Expires 11/23/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Speedway, LLC P.O. Box 1500 Springfield, OH 45501</p> <p>Contact: Zachary Davis (937) 203-7827</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Speedway #7423 201 North Avenue Ina, IL 62846</p> <p>Contact: Travis Powell (937) 863-6513</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 9, 10) - 20,000, (TK # 13) - 8,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 9, 10, 13) Piping - Shear Valves*

(d) *Product to be stored in each tank: (TK # 9, 10, 13) - B-11*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

THIS NEW PERMIT IS IN CONJUNCTION WITH PREVIOUS PERMIT # 00530-2022UPG

IMPACT VALVES WERE REPLACED AND TESTED BUT THE TEST RESULTS WERE NOT UPLOADED PRIOR TO INSPECTION-
WILL RESCHEDULE INSPECTION.


NOTE: UDC sumps must be installed if not already existing where shear valves are being replaced

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street

Contact Person: Jimmy Spiros
Phone: (314) 772-4501

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File