



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3047416
Permit # 00551-2022REM
Request Rec'd 05/20/2022
Amended Date
Approval Date 5/27/2022 SB
Permit Expires 11/29/2022

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Proximity Group, LLC 3117 Columbia Street Des Moines, IA 50313 Contact: John Peters (309) 558-5247	(2) <u>FACILITY</u> - name and address where tanks are located: Proximity Group, LLC 406 S. Chambers Street Galesburg, IL 61401 Contact: John Peters (309) 558-5247
--	---

(3) **REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 1, 2, 3, 4) - 2,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1, 2, 3, 4) - Gasoline - Regular*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number: 2022-0424*
- (f) *Date each tank was last used: (TK # 1, 2, 3, 4) - 9/5/1990*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

- (5) **SPECIAL CONTINGENCIES** : Properly remove UST's and associated piping.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

CW3M Company, Inc.
701 West South Grand Avenue
Springfield, IL 62704

Contact Person: Carol Rowe
Phone: (217) 522-8001
Contractor Registration # IL1723 Exp. 8/9/2022

Sincerely,

Shelly Bradley

cc: Storage Tank Safety Specialist
Division File