



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

### Amended

#### FOR OFFICE USE ONLY

Facility # 2014592  
Permit # 00550-2022UPG  
Request Rec'd 05/25/2022  
Amended Date 06/06/2022 DS  
Approval Date 5/25/2022 DS  
Permit Expires 11/27/2022

#### Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

|   |   |
|---|---|
| <b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:<br><br>Speedway, LLC<br>P.O. Box 1500<br>Springfield, OH 45501<br><br>Contact: Zachary Davis (937) 203-7827 | <b>(2) FACILITY</b> - name and address where tanks are located:<br><br>Speedway #7612<br>7218 West Lincoln Highway<br>Frankfort, IL 60423<br><br>Contact: Tommie Toliver (815) 469-1644 |
|---|---|

#### **(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 6, 7, 8) - 12,000, (TK # 9) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 6, 7, 8, 9) Piping - Flexible Double Wall A.P.T. Poly Tech S175SC*
- (d) *Product to be stored in each tank: (TK # 6, 7) - Gasoline - Regular, (TK # 8) - Gasoline - Premium, (TK # 9) - B-11*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

#### **(5) SPECIAL CONTINGENCIES :**

The UDC underneath 3/4 is broken needs so replacing the UDC

WE ARE CHANGING 2 UDC CONTAINMENTS INSTEAD AS WE FOUND ONE MORE BROKEN CONTAINMENT

The UDC underneath 1/2 is broken needs so replacing the UDC

Amendment Reason: WE ARE CHANGING 2 UDC CONTAINMENTS INSTEAD AS WE FOUND ONE MORE BROKEN CONTAINMENT

#### **(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**


America Petropump Services LLC d/b/a Ampsco Services

Contact Person: Ravindra Penmatsa

4075 Fox Valley Center Dr., Unit 9  
Aurora, IL 60504

Phone: (312) 286-6722  
Contractor Registration # IL002420 Exp. 5/22/2023

Sincerely,



---

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File