

City of Chicago Department of Public Health

333 South State Street, Room 200 Chicago, IL 60604 3127453162

FOR OFFICE USE ONLY

Facility # 2026986 Permit # 00615-2022INS Request Rec'd 06/06/2022 Amended Date Approval Date 6/7/2022 Permit Expires 12/7/2022

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business

entity:

Chicago Fuel, LLC 43 N. Homan Avenue Chicago, IL 60624

Contact: Nasir Ali (773) 971-9900

(2) **FACILITY** - name and address where tanks are located:

Garfield Gas, Inc. 43 N. Homan Avenue Chicago, IL 60624

Contact: Nasir Ali (773) 971-9900

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 11) 8,000
- (b) Type of tank(s): (TK # 11) Tank Fiberglass Double Wall Containment Solutions
- (c) Type of piping: (TK # 11) Piping Flexible Double Wall NUPI Smartflex, (TK # 11) Piping Single Wall STP/Tanktop Sump
- (d) Product to be stored in each tank: (TK # 11) E-85
- (e) Type of leak detection being used:

Tank: (TK # 11) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD, (TK # 11) Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors

Piping: (TK # 11) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 11) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown

(f) Corrosion Protection being used:

Tank: (TK # 11) Corrosion Prot - Tank - Fiberglass Non-Corrosive

Piping: (TK # 11) Corrosion Prot - Piping - Flexible Non-Corrosive

- (g) Spill containment devices, piping and dispenser containment devices: (TK # 11) Spill Contain Device Single Wall Spill Bucket
- (h) Overfill prevention devices: (TK # 11) Overfill Prev Device Overfill Drop Tube Valve
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.govor by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS: There shall be a minimum of two manufactured slotted or perforated observation wells of at lease 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Cardinal Compliance LLC Contact Person: Chris Derro

Phone: (708) 452-8620

Contractor Registration # IL002418 Exp. 3/18/2023

Sincerely,

Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist Division File