



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 3031219
 Permit # 00637-2022REL
 Request Rec'd 06/01/2022
 Amended Date
 Approval Date 6/14/2022 DS
 Permit Expires 12/14/2022

Permit for INTERIOR LINING of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to internally line underground storage tank(s) or piping is hereby granted. Such interior lining must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. Such interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Bureau Service Company 22069 U.S. Highway 34 Princeton, IL 61356</p> <p>Contact: Mark Wright (815) 866-1371</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Ag View FS, Inc. 2194 State Rt. 17 Varna, IL 61375</p> <p>Contact: Brad Condit (309) 463-2400</p>
---	---

(3) INTERIOR LINING OF TANKS:

- (a) Number and size of tanks being internally lined: (TK # 5) - 12,000
- (b) Type of tank(s):
- (c) Name of manufacturer of internal lining material: International Paint LLC
- (d) Designation of internal lining material: International Enviroline 375
- (e) Product to be stored in each tank: (TK # 5) - B-99
- (f) Manway accessible at grade: (TK # 5) Install

(4) This permit is VOID if tank is unacceptable for interior lining. Any tank that has been out of service for a twelve month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for interior lining and manway installation only. Separate permits are required to do interior tank lining inspections.

(5) The owner must notify this Office when completion of tank internal lining has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov by calling (217)785-1020.

(6) **SPECIAL CONTINGENCIES** : Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by section 175.500.

Purge, clean, sandblast and line, for fuel compatibility, the interior of the following tank in accordance with NLPA 631 and coating manufactures recommendations. Install one (1) 20" manway on tank. Apply two (2) full coats of Enviroline 375 Advanced Hybrid Epoxy Novolac to tank interior. Inspect for proper cure and coverage.

NOTE: Lining for compatibility purposes

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>Armor Shield of Wisconsin 1875 Highland Court Slinger, WI 53086</p>	<p>Contact Person: Clayton Bennett Phone: (262) 644-6447 Contractor Registration # IL1707 Exp. 4/18/2024</p>

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File