



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 2036454
 Permit # 00666-2022UPG
 Request Rec'd 06/21/2022
 Amended Date
 Approval Date 6/23/2022 SB
 Permit Expires 12/23/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

| | |
|---|--|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Thorntons LLC 2600 James Thornton Way Louisville, KY 40245</p> <p>Contact: Maggie Seaugh (502) 425-8022</p> | <p>(2) FACILITY - name and address where tanks are located:</p> <p>Thorntons #139 418 S. Lincoln Way North Aurora, IL 60542</p> <p>Contact: Chris Vivens (630) 906-1114</p> |
|---|--|

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 20,000*
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular*
- (e) *Type of leak detection being used:*
Tank: (TK # 1) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD
Piping:
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Removing the SIR and Precision Tightness Testing Warren Rogers Assoc. Petro Network S3 Version D option as a form of tank leak detection. Primary form of leak detection will only be the ATG Vedder Root TLS350 with CSLD, which is currently being utilized.

| | |
|---|---|
| <p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> | |
| <p>Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108</p> | <p>Contact Person: Robert Stenstrom Phone: (815) 398-6250 Contractor Registration # IL1890 Exp. 4/12/2024</p> |

Sincerely,

Shelly Bradley

Shelly Bradley

cc: Storage Tank Safety Specialist
Division File