



Office of the Illinois State Fire Marshal  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 2177851020

**FOR OFFICE USE ONLY**  
 Facility # 2036446  
 Permit # 00671-2022UPG  
 Request Rec'd 06/21/2022  
 Amended Date  
 Approval Date 6/23/2022 SB  
 Permit Expires 12/23/2022

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Shrigi, LLC        988 Riverstone Dr.        Aurora, IL 53066</p> <p>Contact: Navin Patel (262) 751-4024</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>BP Amoco #14166        1207 N. Eola Rd.        Aurora, IL 60504</p> <p>Contact: Navin Patel (630) 236-0745</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 10,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 2) - Gasoline - Regular*

(e) *Type of leak detection being used:*

*Tank:*

*Piping: (TK # 2) Leak Detect - Piping - Non-Discriminating Sump Sensor*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Replace existing non-discriminating piping sump sensor

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>Innovative Constructions Technology LLC        3112 AVIARA CT NAPERVILLE IL        Naperville, IL 60564</p>	<p>Contact Person: RAMACHANDRA RAJ penumatsa        Phone: (630) 747-3404        Contractor Registration # IL002453 Exp. 2/7/2024</p>

Sincerely,

Shelly Bradley

Shelly Bradley

cc: Storage Tank Safety Specialist  
Division File