



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
 Facility # 7-043783
 Permit # 01350-2007INS
 Request Rec'd 08/27/2007
 Amended Date
 Approval Date 8/28/2007 JC
 Permit Expires 2/28/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: CJ's Fast Stop Oak Street & Rt. 1 Allendale, IL 62410 Contact: Chuck Bell (618) 943-1505</p>	<p>(2) FACILITY - name and address where tanks are located: CJ's Fast Stop Oak Street & Rt. 1 Allendale, Wabash Co., IL Contact:</p>
---	---

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed:* (TK # 1, 2) - 4,000 gallons
- (b) Type of tanks:* (TK # 1, 2) - (Installing) Containment Solutions single wall fiberglass
- (c) Type of piping:* (TK # 1, 2) - (Installing) A.P.T. Poly Tech P175 SC double wall flexible
- (d) Product to be stored in each tank:* (TK # 1) - Gasoline, (TK # 2) - Diesel Fuel
- (e) Type of leak detection being used:*
Tank: (TK # 1, 2) - (Installing) Red Jacket Pro Plus with CSLD automatic tank gauge
Piping: (TK # 1, 2) - (Installing) Red Jacket FX1 mechanical line leak detector
- (f) Corrosion Protection being used:*
Tank: (TK # 1, 2) - (Installing) Fiberglass
Piping: (TK # 1, 2) - (Installing) Non-corrosive flexible
- (g) Spill containment devices:*
- (h) Overfill prevention devices:*

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

<p>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p align="right">Contact Person: Wm. VonDrehle or Charlie Phone: 217-826-8628 or 217-822-8628 Contractor Registration # Exp.</p>

Sincerely,

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 1/98)